CITY OF NEW YORK DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner MEA 178-04-E

Report of Material and Equipment Acceptance Division

Manufacturer – Rheem Manufacturing Company for RUUD, P.O. Box 17010, Fort Smith, AR 72917-7010.

Trade Name(s) – RUUD.

Product –Condensing and compressor units.

Pertinent Code Section(s) – 27-770, 27-777.

Prescribed Test(s) -RS 13-6 (ANSI B9.10), RS 13-11 (UL 1995).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) - File SA3930, dated May 21, 1999, revised February 20, 2004.

Description – Outdoor air cooled condenser used for refrigeration and air conditioning systems. This is a component comprising of a metal enclosure, condenser coil, fan and fan motor and appropriate controls. Units, with cooling capacities are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity TONS
UAMM024	2.0
UAMM030	2.5
UAMM036	3.0
UAMM042	3.5
UAMM048	4.0
UAMM060	4.5

Recommendation - That the above outdoor air cooled condensers be accepted, under the following conditions:

- All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
- 2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
- 3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Examined By Ryan Rayan