

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

MEA 179-00-M
Report of Materials and Equipment Acceptance Division

Manufacturer – LG Chemical Ltd., #20, Yoido-Dong-Youngdungpo-Gu, Seoul, Korea
Trade Name – LG-Ultra Gloss Supreme.

Product - PVC coated fabric for flex sign.

Pertinent Code Section(s) -27-499, 27-501, 27-506, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701(Test Method 2)].

Laboratory - U.S. Testing Company Inc.

Test Report(s) - U.S. Testing Report No. 140253 dated May 22, 2000.

Description – LG-Ultra gloss supreme is weft inserted knit polyester tarpaulin base fabric. It has 13 oz. per square feet. It can be used for banners, displays, billboards and signage applications.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance JUL 27 2000

Examined By S. Derkshidam