



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 18-98-E Vol. 4

**Manufacturer:** Altronix Corporation, 140 58<sup>th</sup> Street, Brooklyn, N.Y.  
11220

**Trade Name(s):** Altronix

**Product:** Power supplies for access control

**Pertinent Code Section(s):** Subchapters 6 & 17, Reference Standard RS 17

**Prescribed Test(s):** UL 294

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File BP6714, Project 06CA19849, issued  
October 14, 2006

**Description:** Model Striket1 Panic Device Power Controller will operate up to two(2) 24VDC panic hardware devices simultaneously. Each lock output has an adjustable delay timer to control a pair of doors simultaneously or independently. It has a follower relay to trigger external relays or to control automatic door operators. In addition, two(2) un-switched auxiliary voltage outputs are provided for powering card readers, keypads, request to exit PIR's, etc. A programmable FACP interface will either provide or remove power to the lock outputs when activated.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 3, 2007, F.P. Index #0612045.

**Terms and Conditions:** The above-described power supplies for access control are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapters 6 and 17.
2. Installation shall be in accordance with the manufacturer's recommendations and UL standard.
3. The above product shall be used only with approved/accepted panic hardware devices.
4. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance January 18, 2007  
Examined By Donald [Signature]