



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 183-02-M Vol. II

Manufacturer: Copperfield Chimney Supply, Inc., 304 South 20th Street, Fairfield, IA 52556.

Trade Name(s): Copperfield Chimney.

Product: Chimney liner.

Pertinent Code Section(s): 27-869.03(b).

Prescribed Test(s): RS 15-16 (UL 1777).

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File MH13768 dated October 27, 2000.

Description – Homesaver Chimney Liners

Individual Products	Description
Homesaver UltraPro	Type 316 Titanium Stainless Steel, .005" thick, corrugated liner with a tight mechanical roll-lock seam construction. Recommended for wood, wood pellet, coal, oil and Category I gas applications, Available in 3" – 8" diameters, which are UL Listed to the UL 1777 Chimney Liner Standard.

Terms and Conditions: That the above chimney lining system be accepted on condition that all uses, location and installations comply with the New York City Building Code, the manufacturer's instructions and the UL Listing.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance September 29, 2005
Examined by Shyam Prasad SD