



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 183-06-M

Manufacturer: DECOUSTICS LIMITED
65, Disco Road
Toronto, Ontario. M9W 1M2. Canada

Trade Name(s): SOLO 8

Product: Decoustics solo 8 acoustic plank/panel

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5(ASTM E84); Toxicity
ASTM E84 Surface Burning Characteristics
Pittsburgh Test for Combustion Product Toxicity

Laboratory: Bodycote Materials Testing Canada Inc.
Anderson Laboratories Inc.

Test Report(s): ASTM E 84-Report # 05-02-748(D)
Pittsburgh Test for Combustion Product Toxicity-
Test # 634; Sample # V-410

Description – Veneer finished and lacquered, 16mm (5/8”) nominal thickness, FR treated MDF core, with face grooved and back perforated to provide acoustic transparency. An acoustically transparent black mat/tissue is laminated to the back.

Flame spread rating 25- smoked density rating –50

NOTE: In accordance with 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the commissioner; and any material which upon retesting is found not to comply with code requirements set forth in the approval of the commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the commissioner may require the use of such material to be restricted or discontinued if necessary to insure safety.

Terms and Conditions: That the above described panel be accepted for interior finish usage, with Class A flame spread rating as indicated above. Upon exposure to the fire panel did not produce products of decomposition or combustible that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of the above described material shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 21, 2006
Examined by Simon Deshpande