



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 186-08-E

Manufacturer: Unified Brands, Inc.
1055 Mendell Davis Drive
Jackson, MS 39272

Trade Name(s): Unified Brands, Inc.

Product: Gas-fired combination steamer/convection ovens
MEA Index #150-230 – Cooking Appliances

Pertinent Code Section(s): Subchapter 14 and Reference Standard RS 14-2

Prescribed Test(s): RS14-6 (ANSI Z83.11)

Laboratory: CSA International

Test Report(s): Certificate #1997339 issued April 25, 2008.

Description: The TRI-RES20 triple-mode cooking system is a full size gas, combination oven featuring Groen’s new TRI-RES technology, which is an exclusive boilerless steaming reservoir system. Units address the needs of institutional and commercial foodservice operators for steam, convection and combination cooking.

Product Covered

Model No.	Input Rating (Btu/hr)
TRI-RES20G	60,000 (Single Unit)
TRI-RES20GC	60,000 (Single Unit)
(2) TRI-RES20GC	120,000 (Total – two units stacked)

Terms and Conditions: The above gas-fired combination steamer/convection ovens are accepted under the following conditions:

1. Units shall use natural gas only.
2. Units may be installed on combustible flooring. Clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. Units shall be installed in accordance with manufacturer's instructions and RS 15-1 (ANSI Z223.1 - the National Fuel Gas Code) requirements.
4. The installation shall not interfere with combustion air, accessibility for operation and servicing.
5. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
6. Special precautions regarding fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
7. For grease removal, suitable baffle type grease filters, MEA-accepted, shall be installed.
8. Gas line tubing and fitting connector shall permit flexibility for operation, cleaning and servicing, and shall be MEA-accepted for such use.
9. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.
10. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
11. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
12. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
13. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance August 26, 2008
Examined By Donald [Signature]