



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 187-05-E (Correction)

Note: This publication reflects revisions to the Terms and Conditions Section, Supecedes, in the entirety the Publication of May 4, 2006.

Manufacturer: Gaylord Industries, 10900 Southwest Avery Street,
Tualatin, Oregon 97062-1149

Trade Name(s): Gaylord Industries

Product: Commercial cooking ventilator.

Pertinent Code Section(s): 27-777

Prescribed Test(s): RS 13-3 (UL 710)

Laboratory: Underwriters Laboratories

Test Report(s): No. MH11403, dated October 28, 2002.

Description – Series CG3-UV Commercial cooking ventilators incorporate UVC lamps, and a high velocity type grease extractor with an air inlet opening above and parallel to the cooking surface. Units are to be mounted over commercial cooking equipment such as fryers and ranges, and are intended for use in high volume application, and/or applications with long grease duct lengths. They are equipped with automatic water/detergent wash systems. Ventilator lengths range from 4 to 16 feet per section. They are designed for use in connection with a 120 volt single phase, 60 Hz, AC power input.

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, The Bureau of Fire Prevention has no objections letter dated 6/28/2005, FP Index #0506002A.

Terms and Conditions: The above described commercial cooking ventilators, when installed in accordance with the instructions supplied by the manufacturer and Reference Standard RS 13-3, are accepted as conforming to Code requirements for grease extractors for exhaust hoods. Installation of grease filters and grease extraction devices shall be as prescribed by the Code and shall be accepted by this Division. All shipments and deliveries of such exhaust hoods shall be provided with a permanent die stamped identification on the units themselves certifying that the exhaust hoods shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation. Further Terms and condition shall be complied with the following:

1. Models provided with exhaust Dampers shall be permitted.
2. Power supply and wiring for controls, luminaries and UV lamps, shall comply with the requirements of the New York City Electrical Code.
3. Actuation of the fire protection system shall cause the shutdown of power to these referenced ventilators.
4. Water connection to mod CG3-UV shall comply with the requirement of the New York City Environmental Protection and the New York City Department of Health.
5. The UV lamps shall be arranged in such a manner than any misplacement or removal of protective barriers and/or covers for UV lamps shall render the UV lamps inoperative. Warning signs shall be provided as per UL requirements (File MH11403).
6. All maintenance and inspection shall be conducted as per requirements of New York City.

Final Acceptance 5/4/06
Examined by Slyan M. Grassano