



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 191-05-E

Manufacturer: Gaylord Industries, 10900 Southwest Avery Street, Tualatin, Oregon 97062-1149

Trade Name(s): Gaylord Industries

Product: Commercial cooking ventilator

Pertinent Code Section(s): 27-777

Prescribed Test(s): RS 13-3 (UL 710)

Laboratory: Underwriters Laboratories

Test Report(s): No. MH13522, dated October 28, 2002; revised August 24, 2004

Description – Series GX2-UV Commercial cooking ventilators incorporate UVC lamps, and a removable high velocity centrifugal grease extractor with an air inlet opening above and parallel to the cooking surface. Units are to be mounted over commercial cooking equipment such as fryers and ranges, and are intended for use in high volume application, and/or applications with long grease duct lengths. Extractors are to be removable for periodic cleaning from the floor area directly in front of the cooking equipment. Ventilator lengths range from 4 to 16 feet per section. They are designed for use in connection with a 120 volt single phase, 60 Hz, AC power input.

Terms and Conditions: The above described commercial cooking ventilators, when installed in accordance with the instructions supplied by the manufacturer and Reference Standard RS 13-3, be accepted as conforming to Code requirements for grease extractors for exhaust hoods. Installation of grease filters and grease extraction devices shall be as prescribed by the Code and shall be accepted by this Division. All shipments and deliveries of such exhaust hoods shall be provided with a permanent die stamped identification on the units themselves certifying that the exhaust hoods shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department before installation.

Final Acceptance 5/4/06

Examined by Guyon M. Prasad