



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 191-07-E

Manufacturer: Petra Engineering Industries Co., Medina Munawara Street, Amman, Jordan 11814

Trade Name(s): Petra Engineering

Product: Packaged Air-conditioning units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995)

Laboratory: Intertek ETL Semko

Test Report(s): No. 3015039-002, re-issued July 20, 2006.

Description: Packaged air-conditioning units with hermetic compressor(s), suitable for outdoor installation and permanently connected to a power source.

Product Covered

Model is **PPH**, followed by 4, 5, 6, 7, 7.5, 10, 11, 13, 13.5, 15, 17, 18.5, 20, 25, 27.5, 30, 35, 36, 40, 42, 45, 50, 55, 57, 60, 62, 65, 70, 80, 85, 90, 95, 100, 105, 115, 125, 130, 135, 160, 180, 200, 220, 250, 275 and 300. (Unit capacity in tons of air-conditioning is identified by the model number - 4 tons through 300 tons).

Terms and Conditions: The above-described units are accepted under the following conditions:

1. Units are for residential and commercial use.
2. Units are for outdoor installation only.
3. Units may use Refrigerant R-410A, R-22, R-407C or R-134a only.
4. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closeable shutters and the duct leading thereto shall be without a damper, or (b) dampers and shutters within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
5. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4, as to maximum sound levels permitted for exterior mechanical equipment.
6. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
7. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
8. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 8/29/07

Examined By [Signature]