

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner  
MEA 196-04-E**

**Report of Material and Equipment Acceptance Division**

**Manufacturer – ICECO, P.O. Box 17010, Fort Smith, AR 72917-7010.**

**Trade Name(s) – RUUD.**

**Product –Condensing and compressor units.**

**Pertinent Code Section(s) – 27-770, 27-777.**

**Prescribed Test(s) -RS 13-6 (ANSI B9.10), RS 13-11 (UL 1995).**

**Laboratory – Underwriters Laboratories Inc.**

**Test Report(s) – File SA7930, dated January 30, 2004.**

**Description – Outdoor air cooled condenser used for refrigeration and air conditioning systems. This is a component comprising of a metal enclosure, condenser coil, fan and fan motor and appropriate controls. Units, with cooling capacities are listed below:**

<b>Model No.</b>	<b>Mfr.'s Specified Nominal Cooling Capacity TONS</b>
<b>10AJB18</b>	<b>1.5</b>
<b>10AJB24</b>	<b>2.0</b>
<b>10AJB30</b>	<b>2.5</b>
<b>10AJB36</b>	<b>3.0</b>
<b>10AJB42</b>	<b>3.5</b>
<b>10AJB48</b>	<b>4.0</b>
<b>10AJB60</b>	<b>5.0</b>

**Recommendation - That the above outdoor air cooled condensers be accepted, under the following conditions:**

- 1. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.**
- 2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.**
- 3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.**

Final Acceptance 7/27/04

Examined By Shyam P. Arora