



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 196-05-E

**Manufacturer:** Rheem Manufacturing Co., P.O. Box 17010, Fort Smith, AR 72917-7010

**Trade Name(s):** Ruud

**Product:** Air-cooled condensing and compressor units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11A (UL 1995)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** SA7930 dated May 21, 1999, revised November 30, 2004.

**Description:** Condensing and compressor units, **model UASL**, as tabulated below:

Model Suffix	Nominal Cooling Capacity	
	Tons	BTU/HR
012	1	12,000
018, 019	1.5	18,000
024, 025	2	24,000
030, 031	2.5	30,000
036, 037	3	36,000
042, 043	3.5	42,000
048, 049	4	48,000
060, 061	5	60,000

**Terms and Conditions:** The above-described condensing and compressor units are accepted under the following conditions:

1. Units shall be installed outdoors only.
2. Units shall use only Refrigerant R-410A.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, it shall be in compliance with all provisions of Section 27-770, subdivision 4 of the New York City Building Code as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 1/16/08

Examined By Ryan. [Signature]