



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 197-07-M

Manufacturer: Belimo Aircontrols (USA), Inc.
43 Old Ridgebury Road
Danbury, CT 06810

Trade Name(s): Belimo Aircontrols

Product: Replacement actuators for fire and smoke dampers

Pertinent Code Section(s): RS13 2-2.1.3, 2-3.8, 2-3.9, 3-3.5, 3-4, 4-3

Prescribed Test(s): RS 13 (UL 873 and UL 555/UL 555S)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File E108966

Description: Actuators, models FSLF, FSNF and FSAF are designed for replacing actuators for MEA-accepted fire and smoke dampers.

Terms and Conditions: The above replacement actuators are accepted with the following conditions:

1. Dampers shall be installed in accordance with the Underwriters Laboratories, Inc, and/or Belimo Air Controls' damper manufacturer.
2. All uses, locations and installations shall comply with the New York City Building Code and the manufacturer's installation instructions.
3. Replacement actuator must be equal or better than the original.

4. Damper and actuator must be functionally tested after replacement.
5. If any structural modifications to the building are made to gain access to the damper, then a permit and inspection are required.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance November 29, 2007

Examined By Simon Deshpande