



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 199-05-E

**Manufacturer:** Rheem Manufacturing Co., A/C Division, P. O. Box 17010, Fort Smith, AR 72917

**Trade Name(s):** Rheem

**Product:** Air handler and fan coil units

**Pertinent Code Section(s):** 27-770, 27-777

**Prescribed Test(s):** RS 13-11A (UL 1995), RS 13-11B (ANSI B9.1), RS14.6 (ANSI Z21.47)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File SA7930, dated November 14, 1994, and revised June 22, 2004

**Description:** Air handler and fan coil units designed for indoor installation and suitable for use with heat pump or air conditioner for upflow, in vertical or horizontal position. R-410A is the refrigerant used for the system. Unit is comprised of fin and tube-type evaporator, evaporator blower and pertinent safety controls. Units, with model numbers, cooling and heating capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity, Tons	Mfr.'s Specified Nominal Heating Capacity, BTUH
RBHL-25*	3.5 or 4.0	42,000 – 48,000
RBHL-26*	5.0	60,000

\*= Contains suffixes

**Terms and Conditions:** The above-described air handler units are accepted under the following conditions:

1. Units shall use Refrigerant R-22 only.
2. Units shall be installed indoors only.
3. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 6/4/07

Examined By Ryan. P.