

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Ronny A. Livian, P.E., Acting Commissioner
MEA 2-02-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Honeywell.

Product – Fire alarm equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Tests – UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S3705, Project 18471/S470, Volume 3, Section 1, issued October 28, 1987 and revised November 21, 2001 and UL letter dated December 26, 2001.

Description – Honeywell Control unit accessory modules as follows:

Model No.	Description
TC810R1024	Relay Control Module
TC810N1013	Supervised Control Module
TC809A1059	Monitor Module
TC841A1000	Conventional Zone Interface Module
TC809B1008	Mini-Module

Pursuant to “Promulgation of the Rules relating to Material and Equipment Application Procedures” dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated January 11, 2002, F.P. Index 0201005.

Recommendation - That the above units be accepted on condition that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3, including the NFPA as appropriate, the UL Listing, manufacturer's instructions, the Fire Department Directives, and with the Electrical Code of the City of New York.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

March 29, 2002

Examined by

Mark Kelly