

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 206-03-E

Report of Materials and Equipment Acceptance Division

Manufacturer – Wolf Range Co., 19600 S. Alameda Street, Compton, CA 90221.

Trade Name(s) – Cecilware.

Product – Gas fired commercial hot plates.

Pertinent Code Section(s) – 27-800, 27-826, RS 14-2 (ANSI Z223.1).

Prescribed Tests – RS 14-6 (ANSI Z83.11).

Laboratory – Canadian Standards Association.

Test Report – No. 1093070 dated June 16, 2003.

Description – Gas fired commercial hot plates, as tabulated below. Units comprise main burner, pilot burner, thermocouples, safety shut off device, pressure regulator, and manual valve.

Model No.	Top Broiler Btu/hr
HDS12X1-(1-999)	1 @ 30,000
HDS12X2-(1-999)	2 @ 30,000
HDS12SU-(1-999)	2 @ 30,000
HDS24X2-(1-999)	2 @ 30,000
HDS24X4-(1-999)	4 @ 30,000
HDS24SU-(1-999)	4 @ 30,000
HDS36X3-(1-999)	3 @ 30,000
HDS36X6-(1-999)	6 @ 30,000
HDS36SU-(1-999)	6 @ 30,000
HDS48X4-(1-999)	4 @ 30,000
HDS48X8-(1-999)	8 @ 30,000
HDS48SU-(1-999)	8 @ 30,000

Note: Minimum installed clearances for combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above commercial hot plates, be accepted, when fired by natural gas only, under the following conditions:

1. Unit shall be installed in accordance with manufacturer's instructions and National Fuel Gas Code and New York City Building Code requirements.
2. The installation shall not interfere with combustion air, accessibility for operation and servicing.
3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
4. Special precautions regarding exhaust fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
5. Gas line tubing and fitting connectors shall permit flexibility for operation, cleaning and servicing, and shall be MEA accepted for such use.
6. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.
7. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
8. All shipments and deliveries of such equipment shall be provided with a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
9. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 9/25/03

Examined by Stephen M. [Signature]