

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

**MEA 21-00-M
Report of Material and Equipment Acceptance Division**

Manufacturer – American Stair Corporation, 642 Forestwood Drive, Romeville, Illinois 60446.

Trade Name – American Stair Endura.

Product – Fiber reinforced cement board for stair treads/steps and landing.

Pertinent Code Section(s) – 27-348.

Test(s) - Noncombustibility.

Laboratory – VTEC Laboratories Inc.

Test Report(s) – VTEC #100-1065-1, dated November 19, 1999.

Description – Fiber reinforced cement board mounted to a metal backing and installed in American Stair Corporation stair system. They are intended for use in stair treads/steps and landings. The product is approved as noncombustible material.

Recommendation – That the above described material be accepted as noncombustible material for use as stair treads/steps and landing. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance JAN 28 2000

Examined By S Derksham