



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 211-07-M

Manufacturer: Foam Products Corporation, 350 Beamer Road S.W.,
Calhoun, GA 30701

Trade Name(s): Silencer FR

Product: Underlayment for flooring

Pertinent Code Section(s): Section 27-335.1(2)
Section 27-348

Prescribed Test(s): RS 5-5 and Toxicity

Laboratory: Southwest Research Institute (SwRI)

Test Report(s): SwRI Report No. 01.12696.02.015, dated 2/1/2007.
SwRI Report No. 01.12693.01.074, dated 2/15/2007.

Description: Orange-colored, synthetic rubber foam (17.7 oz/sy), acoustical underlayment is intended for use with wood flooring. The synthetic rubber foam has a nominal thickness of .08 inch (2.1 mm), nominal weight of 0.1 lb/ft² (0.4kg/m²) and nominal density of 12.1 lb/ft³ (0.19g/cm³).

Flame spread rating – 5
Smoke density rating – 85

Terms and Conditions: The above-described material is accepted for use as underlayment for finish flooring under the following conditions:

1. The material may be used when a Class "A" flame-spread rating is required.
2. The material shall be used with wood flooring.
3. The material shall be used in accordance with the New York City Building Code.
4. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance October 22, 2007

Examined By Srin Deshpande