



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 216-91-E Vol.2

**Manufacturer:** Vogt Tube Ice, 1000 West Ormsby Avenue, Suite 19, Louisville, KY 40210

**Trade Name(s):** Tube-Ice Machines

**Product:** Commercial ice maker

**Pertinent Code Section(s):** 27-771, 27-777

**Prescribed Test(s):** RS 14-6 (UL 471)

**Laboratory:** Underwriters Laboratories Inc.

**Test Report(s):** File SA3831, Volume 1, Section 7, dated 11/24/97;  
 File SA3831, Volume 1, Section 8, dated 1/6/99

**Description:** Commercial ice makers are listed below. Unit is comprised of control box, expansion valve, compressor, either air or water-cooled condenser, dryer, receiver, and condenser fan. Evaporative compartment is equipped with evaporator, water pump, float valve, and ice sensor probe. R-22 is the refrigerant used.

02KA-PFB4-26	03KA-PFB4-26	04KA-PFB4-26	03TA-PFB4-26
02KA-PFK4-26	03KA-PFK4-26	04KA-PFK4-26	03TA-PFK4-26
02KA-PFD4-26	03KA-PFD4-26	04KA-PFD4-26	03TA-PFD4-26
02KA-PFB5-26	03KA-PFB5-26	04KA-PFB5-26	03TA-PFB5-26
02KA-PFK5-26	03KA-PFK5-26	04KA-PFK5-26	03TA-PFK5-26
02KA-PFD5-26	03KA-PFD5-26	04KA-PFD5-26	03TA-PFD5-26
02KA-PFB4-46	03KA-PFB4-46	04KA-PFB4-46	03TA-PFB4-46
02KA-PFK4-46	03KA-PFK4-46	04KA-PFK4-46	03TA-PFK4-46
02KA-PFD4-46	03KA-PFD4-46	04KA-PFD4-46	03TA-PFD4-46
02KA-PFB5-46	03KA-PFB5-46	04KA-PFB5-46	03TA-PFB5-46
02KA-PFK5-46	03KA-PFK5-46	04KA-PFK5-46	03TA-PFK5-46
02KA-PFD5-46	03KA-PFD5-46	04KA-PFD5-46	03TA-PFD5-46

**Terms and Conditions:** The above commercial ice makers are accepted under the following conditions:

1. Units shall be installed in accordance with the manufacturer's instructions and the New York City Electrical Code.
2. The installation shall not interfere with accessibility for operation and servicing.
3. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use as provided for in Section 27-131 of the Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 8/28/06

Examined by Shyam Prasad

