



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 219-02-E Vol. 7

Manufacturer: System Sensor, A Div. of Honeywell Int'l, 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Mircom, System Sensor

Product: Smoke detectors

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17-3

Prescribed Test(s): UL 268

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): ML File S6295 issued April 2, 2001 and revised August 20, 2002.

Description: Mircom photoelectric smoke detectors are multiple-listed as follows:

System Sensor, Division of Pittway Corp. Basic Applicant's (Supplier's) Product/Module Designation	Mircom Technologies, Ltd. Multiple Listee's Product/Module Designation
2251B	MIX-2251B
2251TB	MIX-2251TB
2251TMB	MIX-2251TMB

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and with Reference Standard RS 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard.
2. Periodic sensitivity tests, where required, shall be conducted in accordance with the regulations of the Fire Department.
3. These units shall be used with compatible UL-listed and MEA-approved fire control panels. The compatibility must be specified or determined by a UL test report or the Engineer of Record.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance July 17, 2007.

Examined By

Donald 