



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 220-05-E

Manufacturer: Off The Wall Fires Ltd, #106-20050 Stewart Crescent, Maple Ridge, British Columbia

Trade Name(s): ThermArt LE.

Product: Gas fired decorative log appliance.

Pertinent Code Section(s): 27-800

Prescribed Test(s): RS 14-6 (ANSI Z21.88).

Laboratory: Intertek ETL

Test Report(s): No. 476-3076547 dated June 14, 2005.

Description – Gas fired decorative log appliance designed to provide supplemental heating and to enhance the aesthetics of a room. The input ratings of natural gas 25,000 BTUH. The model ThermArt LE is vented from the top of the appliance using listed 4” x 6-5/8” American Metal Products AmeriVent Direct System.

Minimum Clearances to Combustibles

Within Recess :	
Back	1.5 inches (40mm)
Sides	0.5 inches (15mm)
Floor	1.0 inches (25mm)
Top	6.0 inches (150mm)
Recess Depth	6.0 inches (150mm)
Flue – Top	2.0 inches (50mm)
Flue – Bottom and Sides	1.0 inches (25mm)
Wall Thimble (Vent Heat Shield)	0.5 inches (15mm)

Note: Appliance heat shield must protrude at least 3 inches from the front wall.
Faceplate upper holes shall not be plugged or restricted to any degree.

Terms and Conditions: That the above described gas-fired log appliance be accepted for use in vented fireplaces only, for decorative heating operation on natural gas only, and for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 12/19/05
Examined by Shyam Prasad