



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 223-05-E

Manufacturer: A.A. International Trading Inc. 171 Bowery St. New York, NY 10002

Trade Name(s): A.A. International.

Product: Gas Fired Commercial Steam Tables.

Pertinent Code Section(s): 27-800, 27-826, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z83.11)

Laboratory: CSA International

Test Report(s): No. 226620-KS44X3, dated July 22, 2005

Description – Gas Fired commercial steam tables, as tabulated below. These are food warmers. Units comprise main burner, pilot burner, manual and safety valves.

Model No.	No. of Warmers	Input Rating BTUH
AA ST-1	1	1x25,000
AA ST-2	2	2x25,000
AA ST-3	3	3x25,000
AA ST-4	4	4x25,000
AA ST-5	5	5x25,000
AA ST-6	6	6x25,000
AA ST-7	7	7x25,000

Note: Clearances to combustible construction should be as followed: Back 4”, Night-side 1”, and Left-side 1”

Terms and Conditions: That the above commercial steam tables be accepted, when fired by natural gas only, under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and National Fuel Gas Code requirements.
2. Gas line tubing and fitting connectors shall permit flexibility for operation, cleaning and servicing, and shall be MEA accepted for such use.
3. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing the unit.
4. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
5. All shipments and deliveries of such equipments shall be provided with a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
6. Approval of all electrical equipment, apparatus, materials, and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 5/17/06

Examined by Steve M. Prasad