



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 225-02-E Vol.5

**Manufacturer:** System Sensor, Unicorp. Division of Honeywell, Intl. Inc., 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** Silent Knight, 7550 Meridian Circle, Maple Grove, MN. 55369

**Product:** Photoelectric Smoke Detector

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard RS17

**Prescribed Test(s):** UL 268

**Laboratory:** Underwriters Laboratories, Inc. (UL)

**Test Report(s):** UL Multiple Listing File S6173, issued July 21, 2005, revised January 10, 2006.

#### Description -

<u>System Sensor Model No.</u>	<u>Silent Knight Model No.</u>	<u>Description</u>
FSP-851	IDP-PHOTO	Photoelectric Smoke Detector
FSP-851T FAPT-851	IDP-PHOTO-T IDP-ACCLIMATE	Photoelectric Smoke Detector with Heat Detector

**Terms and Conditions:** The above smoke detectors be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard RS17-3 and UL listing. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of the Fire Department. These units shall be used with a compatible UL listed and MEA approved base and fire control panel. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance April 26, 2006  
Examined by Donald J. Ad