



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 225-06-E

Manufacturer: International Comfort Products, LLC, 7310 West Morris Street, Indianapolis, Indiana 46231

Trade Name(s): Heil, Comfortmaker, Airquest, Arcoaire, ICP Commercial, KeepRight, Tempstar, Kenmore

Product: Single-packaged rooftop air conditioner

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS13-11 (UL465, UL1995)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA11583, Volume 7, Section 10, dated December 21, 2005

Description: Single-packaged cooling unit designed for rooftop or outdoor installation. R-22 is the refrigerant used for the system. Unit is comprised of a scroll compressor, air-cooled condenser with fan, and safety controls. Units, with model numbers and cooling capacities, are listed below:

Model Number	Mfr.'s Specified Cooling Capacity (BTUH)
PAF324000-***	23,000
PAF330000-***	28,600
PAF336000-***	35,000
PAF342000-***	40,000
PAF348000-***	44,500
PAF360000-***	53,000

- indicates voltage

* indicates options

Terms and Conditions: The above-described rooftop air-conditioning units are accepted under the following conditions:

1. Units shall be installed outdoors only.
2. Units shall use only refrigerant R-22.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance January 18, 2007

Examined By Simon Derkhdan