



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 227-94-M Vol. 4

Manufacturer: The Schebler Company, 5665 Fenno Road, Bettendorf, IA 52722

Trade Name(s): Schebler

Product: Chimney flue for boilers and hot water heaters

Pertinent Code Section(s): 27-855

Prescribed Test(s): RS 15-11

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): MH10056 dated February 21, 2007, revised August 21, 2007.

Description: Factory-built chimney flues, models **PAL** and **P2L**, designed for boilers and hot water heaters, intended for the venting of liquid or gas fuel exhaust gases, at a temperature not exceeding 1400°F under continuous operating conditions in accordance with Reference Standard RS 15-11.

The model **PAL** special gas vent system is comprised of a stainless steel inner wall with a stainless steel outer wall. The annular space between the inner and outer walls is 1.00 inch (25 mm).

The model **P2L** special gas vent system is comprised of a stainless steel inner wall, stainless steel outer wall and 2 inches of insulation between the inner and outer walls.

Both models are two-walled special gas vent systems in sizes 5 inches (127 mm) through 28 inches (1,219mm).

Terms and Conditions: The above-described factory-built chimney flues are accepted for use with the following conditions:

1. These chimneys shall be identified as "1400 Degree Fahrenheit Chimney part" and installed in accordance with installation instructions provided by the manufacturer and in accordance with all provisions of New York City Building Code, specifically Subchapter 15, Section 27-885, 27-864 and 27-869.01 for Listed Factory Built chimneys. All interior factory-built chimneys shall be enclosed in accordance with the Building Code.
2. The chimneys shall not be enclosed with combustible materials.
3. Installation shall be in accordance with the manufacturer's recommendation and UL Standard.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 12/13/07
Examined By Shyam A. J.