

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 229-00-E

Report of Material and Equipment Acceptance Division  
Manufacturer - System Sensor, A Division of Pittway, 3825 Ohio Avenue  
St. Charles, IL. 60174, Listee Notifier, One Fire-Lite Place, Northford,  
CT 06472.

Listee - Notifier, One Fire-Lite Place, Northford, CT 06472.

Trade Name(s) - System Sensor and Notifier - Listee.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - Reference Standard RS 17-3, RS 4-6 (886-89-BCR).

Applicable Test(s) - UL 268, UL 864, UL 521, UL 539.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL file S911, Project 98NK390031, Volume 31, Section 3, Issued June 9, 1999, revised May 5, 2000 and UL letter dated June 8, 2000 and UL letter File S911 issued May 12, 1994 and revised April 27, 2000.

Description - System Sensor's and Notifier's (listee) Photoelectric with heat Smoke Detector as follows:

Model No.	Description
FAPT-751	Photoelectric W/Heat Smoke Detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated May 23, 2001, F.P. Index No. 0006064A.

Recommendation - That the above smoke detector be accepted on conditions that all uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3 and the UL Listing. Further, the installation shall be in accordance with the manufacturer's recommendation. This unit shall be used only with listed and approved control panels with which the compatibility has been determined by a nationally recognized laboratory test report.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance June 19, 2001  
Examined Mark Jacoby