

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 23-00-E

Report of Material and Equipment Acceptance Division
Manufacturer - Systems Sensor, A Division of Pittway, 3820 Stern Avenue,
St. Charles, IL. 60174

Trade Name(s) - FCI, System Sensor.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - RS 17-3, RS 4-6 (886-89-BCR).

Test(s) -

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL ML file S1913, issued December 2, 1986.

Description - Multiple listing of System Sensor's smoke detector as follows:

Fire Control Instruments, Inc. Multiple Listee's Product/Module Designation	System Sensor, Div. of Pittway Corp. Basic applicant's (Supplier) Product/Module Designation
ASD-PTL	2251T

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention had no objection for equivalent model numbers under MEA 205-94-E Vol. III, letter dated December 30, 1999 F.P. Index No. 9912062.

Recommendation - That the above smoke detectors be accepted on conditions that all uses shall comply with the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3 and UL listing. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. Periodic sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 13, 2000

Examined By Mark Feely