



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 230-06-E

**Manufacturer:** Above Air Technologies, 4844 Winchester Boulevard, Frederick, MD 21703

**Trade Name(s):** Spot Cool, HK Horizontal

**Product:** Room Air Conditioning

**Pertinent Code Section(s):** 27-770, 27-777.

**Prescribed Test(s):** RS 13-11 (UL1995), RS 13-6 (ANSI B9.1)

**Laboratory:** Intertek Testing Services

**Test Report(s):** No. 3088907-004, 005. 006 Dated March 28, 2006

**Description** – Horizontal ceiling-mounted, packaged and split DX coils and chilled water air conditioners and heat pumps for commercial and residential use as listed below:

INDIVIDUAL PRODUCTS	MODEL NOS.
SPOT COOL™ 2X4 CEILING MTD AIR CONDITIONERS & HEAT PUMPS (1-3 TONS)	SPA.SPC,SPE, SPH, SPG,SPW,CCU,CCX,CGU, CGX, CWU, CWX-012, 018, 024, 030 & 036
HK™ HORIZONTAL CEILING MTD AIR CONDITIONERS & HEAT PUMPS (1-30 TONS)	AAC/P, ACC/P, AEC/P, AGC/P, AWC/P, XCU/X, XGU/X, XWU/X- 012, 024, 030, 036, 048, 060, 072, 090, 096, 120, 144, 180, 240, 300, 360

**Terms and Conditions:** The above Air Conditioners are accepted under the following conditions:

1. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of electrical equipment, apparatus, materials and devices shall be obtained from the Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance \_\_\_\_\_

7/28/06

Examined by \_\_\_\_\_

Shyam N. Prasad