



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 232-06-E

**Manufacturer:** Honeywell International, Inc.  
12 Clintonville Road  
Northford, CT 06472

**Trade Name(s):** Notifier

**Product:** NFS2-3030 Addressable Fire Alarm Control Unit

**Pertinent Code Section(s):** 27-968 thru 27-977, Reference Standard RS 17.

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S635, Project 05NK09345, issued September 30, 2005. UL File S635, Project 01NK16253, issued August 7, 2001, revised December 5, 2005. UL File S635, Project 05NK09345, issued September 28, 2005, revised February 15, 2006.

**Description:** The Notifier model NFS2-3030 addressable fire alarm control unit is UL Listed to the 9<sup>th</sup> Edition, UL 864 and has releasing capability. It is similar to and uses the same optional equipment as the NFS-3030 (MEA 345-02-E) with the addition of the following models:

Model	Description
CPU2-3030D/-3030ND	CPU Modules
DVC/-EM	Digital Voice Control Modules
DAA- 5025/-5070	Digital Audio Amplifiers
DAA-PS	Power Supply
DVC-KD	Keyboard
TELH-1	Telephone Interface

<b>CA-1/-2</b>	<b>Chassis</b>
<b>CHS-4N</b>	<b>Chassis</b>
<b>CMIC-1</b>	<b>Microphone</b>
<b>CHS-BH1</b>	<b>Battery Chassis</b>

<b>ADDR-B4/-B4R; - ADDR-D4/-D4R</b>	<b>Doors</b>
<b>NFS-LBB</b>	<b>Battery Box</b>
<b>BP2-4</b>	<b>Battery Panel</b>
<b>DPA-1/-1A4/-2(B)</b>	<b>Dress Panels</b>
<b>NCA-2</b>	<b>Network Control Annunciator</b>

**Terms and Conditions:** That the above units be accepted on condition that:

1. All uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3, 17-3A, 17-3B, 17-3C and 17-5. Further, the installation shall be in accordance with the manufacturer's recommendations and UL Standards.
2. The installation of Fire Alarm Control Unit must provide for fail-safe operation. This feature must assure that control of doors, locks, ventilation fans, and elevator recall will not be rendered inoperable in the event of a fire or power failure.
3. The control unit when used with central office communicator or transmitter (DACT), the installation and operation of the equipment and devices shall comply with 3RCNY §17-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler water flow alarm, supervisory signal indications and trouble indications.
4. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate same.
5. Digital notification and voice system shall have the capability of individual, group or entire building notification of alarm tone and voice intelligibility.
6. Installation of pre-recorded evacuation messages in the fire alarm control unit would require a prior approval from the Department.
7. Prior approval shall be required from the Fire Department when the above referenced control units are employed for smoke control applications.
8. All above referenced fire alarm equipment shall be painted red in color.
9. All enclosing cases for above fire alarm, sprinkler alarm, smoke detection and associated systems alarm apparatus shall be painted fire department red, except where approval is given by the commissioner to deviate from this requirement. The lobby information display system may be painted or finished to suit the owner of the building.

10. The above referenced fire alarm control units shall be used only with listed, approved or accepted equipments and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.

**NOTE:** In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the commissioner; and any material which upon retesting is found not to comply with code requirements or the requirements set forth in the approval of the commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 22, 2006.  
Examined by Donald [Signature]