



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 235-87-E Vol. 6

**Manufacturer:** Nor-Lake, Inc., 2<sup>nd</sup> and Elm Streets, Hudson, Wisconsin 54016

**Trade Name(s):** Nor-Lake

**Product:** Milk coolers

**Pertinent Code Section(s):** 27-771, 27-772

**Prescribed Test(s):** RS 14-6 (UL 471)

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File SA9742, dated May 24, 2006

**Description:** Self-contained milk coolers as tabulated below. These milk coolers are comprised of on/off switches, refrigeration controllers, condensing units, evaporators and evaporator fan motors. The condensing units are equipped with compressors, starting capacitors, condensers, condenser fans, receivers and fan motors. The condensing units and evaporators are thermostatically-controlled. The air input and exhaust grills located on the condensing unit enclosures allow for even air circulation to the condensing units.

Model No.	Refrigerant		High Side PSIG	Low Side PSIG	Operating Voltage
	Type	Amount			
DR082SSS/0	R134a	6.5 oz.	204	88	115VAC
DR082WWS/0	R134a	6.5 oz.	204	88	115VAC
DR082WSS/0	R134a	6.5 oz.	204	88	115VAC
DR082WVS/0	R134a	6.5 oz.	204	88	115VAC
DR084SSS/0	R134a	6.5 oz.	204	88	115VAC
DR084WWS/0	R134a	6.5 oz.	204	88	115VAC

Model No.	Refrigerant		High Side PSIG	Low Side PSIG	Operating Voltage
	Type	Amount			
DR084WSS/0	R134a	6.5 oz.	204	88	115VAC
DR084WVS/0	R134a	6.5 oz.	204	88	115VAC
DR0122SSS/0	R134a	6.5 oz.	215	88	115VAC
DR0122WWS/0	R134a	5.5 oz.	215	88	115VAC
DR0122WSS/0	R134a	5.5 oz.	215	88	115VAC
DR0122WVS/0	R134a	5.5 oz.	215	88	115VAC
DR0124SSS/0	R134a	5.5 oz.	215	88	115VAC
DR0124WWS/0	R134a	5.5 oz.	215	88	115VAC
DR0124WSS/0	R134a	5.5 oz.	215	88	115VAC
DR0124WVS/0	R134a	5.5 oz.	215	88	115VAC
DR0162SSS/0	R134a	5.5 oz.	215	88	115VAC
DR0162WWS/0	R134a	5.5 oz.	215	88	115VAC
DR0162WSS/0	R134a	5.5 oz.	215	88	115VAC
DR0162WVS/0	R134a	5.5 oz.	215	88	115VAC
DR0164SSS/0	R134a	5.5 oz.	215	88	115VAC
DR0164WWS/0	R134a	5.5 oz.	215	88	115VAC
DR0164WSS/0	R134a	5.5 oz.	215	88	115VAC
DR0164WVS/0	R134a	5.5 oz.	215	88	115VAC

**Terms and Conditions:** The above commercial milk coolers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. The installation shall not obstruct access for operation and servicing.
3. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 7/13/07

Examined By Shyam Prasad