



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 240-05-M

**Manufacturer:** Jessup Manufacturing Company  
 2815 W. Route 120 – P.O. Box 366  
 McHenry, IL 60051  
 Phone: 815-385-6650 Fax: 815-385-0079

**Trade Name(s):** Glo Brite®

**Product:** Glo Brite® #7550SR –Film on semi-rigid substrate

**Pertinent Code Section(s):** §27-383(b), Reference Standards RS 6-1 and RS6-1A

**Prescribed Test(s):**

1. - Brightness Rating - ISO 17398:2004
2. - Washability ASTM D 4828-1994 (2003)
3. - Toxicity Bombardier SMP 800-C
4. - Radioactivity ASTM D 3648-2004
5. - Flame Spread ASTM E 162-2002 or ASTM D 635-2003

**Laboratory:** Bodycote Materials Testing NA – Tests: 3 &5  
 California Institute of Electronics & Material Science – Test 4  
 DL Labs Inc – Test 2  
 Intertek Group ETL – Test 1

**Test Report(s):** Bodycote Materials Testing NA – Report #05-02-364(A)  
 5/25/05 and 05-02-485(A) 6/20/05  
 California Institute of Electronics & Material Science  
 Report #850950281 – 5/18/05  
 DL Labs Inc. – Report #DL-14484A-1 – 6/14/05  
 Intertek Group ETL – Report #3078094-002 – 6/9/05

**Description:**

#7550SR Glo Brite® is a photoluminescent film on a semi rigid flame-retardant plastic substrate. This safety grade photoluminescent material is designed to meet requirements of RS6-1 NYC LL26.

Model Number	Catalogue Description	Size (Approx.)
50SR-1SN-F	Directional Sign – Forward	4.5” x 8”
50SR-1SN-UR	Directional Sign – Up Right	4.5” x 8”

50SR-1SN-R	Directional Sign – Right	4.5" x 8"
50SR-1SN-DR	Directional Sign – Down Right	4.5" x 8"
50SR-1SN-D	Directional Sign – Down	4.5" x 8"
50SR-1SN-DL	Directional Sign – Down Left	4.5" x 8"
50SR-1SN-L	Directional Sign – Left	4.5" x 8"
50SR-1SN-UL	Directional Sign – Up Left	4.5" x 8"
50SR-2SN-R	Exit Sign – Right	4.5" x 13"
50SR-2SN-L	Exit Sign – Left	4.5" x 13"
50SR-3SN-R	Final Exit Sign – Right	11" x 8"
50SR-3SN-UR	Final Exit Sign – Up Right	11" x 8"
50SR-3SN-UL	Final Exit Sign – Up Left	11" x 8"
50SR-3SN-L	Final Exit Sign – Left	11" x 8"
50SR-3SN-C	Final Exit Sign – Custom Legend	11" x 8"
50SR-4SN-R	Exit Through Lobby Sign – Right	7" x 16"
50SR-4SN-UR	Exit Through Lobby Sign – Up Right	7" x 16"
50SR-4SN-UL	Exit Through Lobby Sign – Up Left	7" x 16"
50SR-4SN-L	Exit Through Lobby Sign – Left	7" x 16"
50SR-4SN-C	Exit Through Lobby Sign – Custom Legend	7" x 16"
50SR-5SN	Not An Exit Sign	6.5" x 5.5"
50SR-5SN-C	Not An Exit Sign – Custom Legend	6.5" x 5.5"
50SR-6SN-R	Wall Mount Exit Sign – Right	9" x 8"
50SR-6SN-UR	Wall Mount Exit Sign – Up Right	9" x 8"
50SR-6SN-DR	Wall Mount Exit Sign – Down Right	9" x 8"
50SR-6SN-DL	Wall Mount Exit Sign – Down Left	9" x 8"
50SR-6SN-UL	Wall Mount Exit Sign – Up Left	9" x 8"
50SR-6SN-L	Wall Mount Exit Sign – Left	9" x 8"
50SR-6SN-C	Wall Mount Exit Sign – Custom Legend	9" x 8"
50SR-7SN-E	Door Handle Markers – Exit	6" x 4"
50SR-7SN-P	Door Handle Markers – Push	6" x 4"
50SR-7SN-C	Door Handle Markers – Custom Legend	6" x 4"
50SR-8SN-C*	Stairwell & Floor Sign – Custom Legend	10" x 10"
50SR-DH	4" x 4" Semi Rigid Door Marker	4-1/16" x 4-1/16"
50SR-DH-C	Custom Semi Rigid Door Marker	16 sq. in. min.
50SR-L1	1" x 3" x 9" Semi Rigid Stair Marker	1" x 3" x 9"
50SR-L2	2" x 4" x 9" Semi Rigid Stair Marker	2" x 4" x 9"
50SR-L1-C	1" x 3" x Custom Semi Rigid Stair Marker	1" x 3" x custom
50SR-L2-C	2" x 4" x Custom Semi Rigid Stair Marker	2" x 4" x custom
50SR-1	1" x 25 Ft. Semi Rigid Rolls	1" x 25 ft.
50SR-2	2" x 25 Ft. Semi Rigid Rolls	2" x 25 ft.
50SR-1x48	1" x 48" Semi Rigid Strip	1" x 48"
50SR-2x48	2" x 48" Semi Rigid Strip	2" x 48"

**Notes:**

- \* The model(s) with asterisks comply with laboratory tests but do not satisfy the design and/or dimensional requirements for mandatory installations under Section 2.1 and 2.2 of RS6-1. These models with asterisks may be installed only as “additional signs and markings” under section 2.5 of RS 6-1.

**Terms and Conditions:**

1. Pathway markings of green color shall be in compliance with ANSI Z535.1 Safety Color Code.

2. Arrows and egress symbols shall comply with ISO 7010 E001, E002, E003, E004.
3. All approved materials shall be labeled and identified with the model number as well as with MEA No. 240-05-M, BR: 52-12-8 in a minimum of six (6) point type with at least one such identification on each piece of material installed in accordance with RS 6-1.
4. No radioactive materials are used.
5. All signs and markings shall conform to the pictorial representations submitted with this application.
6. All models directing persons to exits are to be installed at a low location so as not to confuse with other required exit signage.
7. No transparent or translucent overlaminates, varnishes, or other coatings shall be applied to the photoluminescent portions of the marking.
8. This acceptance is limited to the materials' use and does not include the installation for compliance with §27-383(b) and Reference Standard 6-1, which is the responsibility of the building owner.

All shipments and deliveries of photoluminescent exit path markings shall be provided with a certification from the manufacturer, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided for in section 27-131 of the Building Code.

Final Acceptance August 4, 2005  
Examined By Donald J. [Signature]