



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 241-05-M

Manufacturer: Jessup Manufacturing Company
2815 W. Route 120 – P.O. Box 366
McHenry, IL 60051
Phone: 815-385-6650 Fax: 815-385-0079

Trade Name(s): Glo Brite®

Product: Glo Brite® #7550F – Flexible Film with Adhesive

Pertinent Code Section(s): §27-383(b), Reference Standards RS 6-1 and RS6-1A

Prescribed Test(s):

1. - Brightness Rating - ISO 17398:2004
2. - Washability ASTM D 4828-1994 (2003)
3. - Toxicity Bombardier SMP 800-C
4. - Radioactivity ASTM D 3648-2004
5. - Flame Spread ASTM E 162-2002 or ASTM D 635-2003

Laboratory: Bodycote Materials Testing NA – Tests: 3 &5
California Institute of Electronics & Material Science – Test 4
DL Labs Inc – Test 2
Intertek Group ETL – Test 1

Test Report(s): Bodycote Materials Testing NA – Report #05-02-339(A)
5/16/05 and Report #05-02-422(A) Rev. 1 – 6/17/05
California Institute of Electronics & Material Science
Report #850950281 – 5/18/05
DL Labs Inc. – Report #DL-14484A-1 – 6/14/05
Intertek Group ETL – Report #3078094-002 – 6/9/05

Description:

Flexible film coated with a high tack pressure sensitive and backed with poly coated release liner. Safety grade photoluminescent material to meet requirements of RS6-1 NYC LL26.

Model Number	Catalogue Description	Size (Approx.)
50F-1SN-F	Directional Sign - Forward	4.5" x 8"
50F-1SN-UR	Directional Sign – Up Right	4.5" x 8"

Model Number	Catalogue Description	Size (Approx.)
50F-1SN-R	Directional Sign – Right	4.5" x 8"
50F-1SN-DR	Directional Sign – Down Right	4.5" x 8"
50F-1SN-D	Directional Sign – Down	4.5" x 8"
50F-1SN-DL	Directional Sign – Down Left	4.5" x 8"
50F-1SN-L	Directional Sign – Left	4.5" x 8"
50F-1SN-UL	Directional Sign – Up Left	4.5" x 8"
50F-2SN-R	Exit Sign- Right	4.5" x 13"
50F-2SN-L	Exit Sign – Left	4.5" x 13"
50F-3SN-R	Final Exit Sign – Right	11" x 8"
50F-3SN-UR	Final Exit Sign – Up Right	11" x 8"
50F-3SN-UL	Final Exit Sign – Up Left	11" x 8"
50F-3SN-L	Final Exit Sign – Left	11" x 8"
50F-3SN-C	Final Exit Sign – Custom Legend	11" x 8"
50F-4SN-R	Exit Through Lobby Sign – Right	7" x 16"
50F-4SN-UR	Exit Through Lobby Sign – Up Right	7" x 16"
50F-4SN-UL	Exit Through Lobby Sign – Up Left	7" x 16"
50F-4SN-L	Exit Through Lobby Sign – Left	7" x 16"
50F-4SN-C	Exit Through Lobby Sign – Custom Legend	7" x 16"
50F-5SN	Not An Exit Sign	6.5" x 5.5"
50F-5SN-C	Not An Exit Sign – Custom Legend	6.5" x 5.5"
50F-6SN-R	Wall Mount Exit Sign – Right	9" x 8"
50F-6SN-UR	Wall Mount Exit Sign – Up Right	9" x 8"
50F-6SN-DR	Wall Mount Exit Sign – Down Right	9" x 8"
50F-6SN-DL	Wall Mount Exit Sign – Down Left	9" x 8"
50F-6SN-UL	Wall Mount Exit Sign – Up Left	9" x 8"
50F-6SN-L	Wall Mount Exit Sign – Left	9" x 8"
50F-6SN-C	Wall Mount Exit Sign – Custom Legend	9" x 8"
50F-7SN-E	Door Handle Markers – Exit	6" x 4"
50F-7SN-P	Door Handle Markers – Push	6" x 4"
50F-7SN-C	Door Handle Markers – Custom Legend	6" x 4"
50F-8SN-C*	Stairwell & Floor Sign – Custom Legend	10" x 10"
50F-DH	4" x 4" Door Marker	4-1/16" x 4-1/16"
50F-DH-C	Custom Door Marker	16 sq. in. min.
50F-L1	1" x 3" x 9" Stair Marker	1" x 3" x 9"
50F-L2	2" x 4" x 9" Stair Marker	2" x 4" x 9"
50F-L1-C	1" x 3" x Custom Stair Marker	1" x 3" x custom
50F-L2-C	2" x 4" x Custom Stair Marker	2" x 4" x custom
50F-1	1" x 100 Ft. Rolls	1" x 100 ft.
50F-2	2" x 100 Ft. Rolls	2" x 100 ft.
50F-1STP	1" x 100 Ft. Rolls Stripe Tape	1" x 100 ft.
50F-2STP	2" x 100 Ft. Rolls Stripe Tape	2" x 100 ft.
50F-3STP	1" x 30 Ft. Rolls Stripe Tape	1" x 30 ft.
50F-4STP	2" x 30 Ft. Rolls Stripe Tape	2" x 30 ft.

Notes:

- * The model(s) with asterisks comply with laboratory tests but do not satisfy the design and/or dimensional requirements for mandatory installations under Section 2.1 and 2.2 of RS6-1. These models with asterisks may be installed only as “additional signs and markings” under section 2.5 of RS 6-1.

Terms and Conditions:

1. Pathway markings of green color shall be in compliance with ANSI Z535.1 Safety Color Code.
2. Arrows and egress symbols shall comply with ISO 7010 E001, E002, E003, E004.
3. All approved materials shall be labeled and identified with the model number as well as with MEA No. 241-05-M, BR: 52-12-8 in a minimum of six (6) point type with at least one such identification on each piece of material installed in accordance with RS 6-1.
4. No radioactive materials are used.
5. All signs and markings shall conform to the pictorial representations submitted with this application.
6. All models directing persons to exits are to be installed at a low location so as not to confuse with other required exit signage.
7. No transparent or translucent overlaminates, varnishes, or other coatings shall be applied to the photoluminescent portions of the marking.
8. This acceptance is limited to the materials' use and does not include the installation for compliance with §27-383(b) and Reference Standard 6-1, which is the responsibility of the building owner.

All shipments and deliveries o/f photoluminescent exit path markings shall be provided with a certification from the manufacturer, certifying that the materials shipped or delivered are equivalent to those tested and accepted for use, as provided for in section 27-131 of the Building Code.

Final Acceptance August 4, 2005
Examined By Donald [Signature]