

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

MEA 245-00-E
Report of Material and Equipment Acceptance Division

Manufacturer - Notifier, One Fire-Lite Place, Northford, CT 06472-1001.

Trade Name(s) - Notifier.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - 27-958 thru 27-977, Reference Standard RS 17-5 ANSI/NfiPA No. 72.

Test(s) - RS 17-5 ANSI/NfiPA No. 72, UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL file S635, Project 00NK9227/52424, Volume 18, Section 6, issued March 15, 2000, revised April 27, 2000.

Description - The FDU-80 Annunciator is a compact, 80 character LCD annunciator for use with compatible fire alarm control panels. Communication between the FDU-80 and the fire alarm control panel is accomplished over a two wire serial interface employing the EIA-485 communication standard. Up to 32 annunciators may be connected to the two wire EIA-485 circuit.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated July 21, 2000, F.P. Index No. 0007010.

Recommendation - That the above annunciators be accepted on conditions that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17, and Reference Standards 17-3. and on further condition that:

1. The operation of this unit shall be limited to display of alarms and functions transmitted to a fire alarm control panel only: No control of activities or override commands shall be allowed from this display panel.
2. This remote display unit shall be utilized only with the listed and approved fire control panels which the compatibility has been determined by UL test report and a MEA resolution.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 14, 2000
Examined Mark Jacobowitz