



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 250-05-M

**Manufacturer:** Superson Ltd., Room 1402-1403 14/F, Lee Kar Building No. 4, Carnarvon Road, Tsimshatsui, Kowloon, Hong Kong.

**Trade Name(s):** Superson Fiberglass Wrap

**Product:** Thermal Duct insulation material.

**Pertinent Code Section(s):** 27-232.

**Prescribed Test(s):** Reference Standard RS 5-5 (ASTM E84).

**Laboratory: Test** Intertek Testing Services.

**Report(s):** Intertek Report No. 3080866-001 dated July 25, 2005.

**Description:** Thermal insulation material form inorganic glass fibers preformed into rolled up sheets, available plain or with multi-purpose, commercial and vinyl facings. Thicknesses of 1, 1 1/2, 2, 2 1/2, and 3 inches are available with various roll lengths. Density of 3A lbs., 1 lbs., and 6 lbs. per cubic foot.

**Terms and Conditions:** That the above fiberglass thermal insulation material be accepted for duct insulation. This acceptance shall not be construed to provide a fire resistance rating for an assembly comprising the insulation, which entire assembly shall be required to be tested under ASTM E119 to determine the fire shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance AUG/15/2005

Examined By Sun Derk Huda