

DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Rudolph J. Rinaldi, R.A., Commissioner

MEA 252-91-E

Report of Material and Equipment Acceptance Division

Manufacturer - Watts Regulator, Watts Industries, Inc., 815 Chestnut Street
North Andover, Ma. 01845

Trade Name - None.

Product - Gate valve.

Pertinent Code Sections RS 17-6A.

Prescribed Tests - RS 17-6A (UL 262).

Laboratory - Underwriters Laboratories, Inc.

Test Reports - Multiple Listing ML file No. EX 4087, issued January 26, 1988.

Description - Gate Valve for fire suppression system.

Model No.	Description	Size	Pressure Rating
Series 408 RW	O.S.Y. Flanged Gate Valve	2 1/2"-12"	175 psig

Recommendation - That the above gate valves be accepted for fire suppression systems in accordance with their U.L rating on condition that all uses, locations and installations comply with the New York City Building Code specifically subchapter 17 and Reference Standard RS-17.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use as provided for in Section 27-131 of the Building Code.

Final Acceptance *Accepted by 1/17/91*
Examined By *Mark J. Feakins*