



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 253-05-E

**Manufacturer:** Max Blank, GmbH, Westheim, Germany for Evolution Trade Group, LLC, 1000 Rand Road, Suite 111, Wauconda, IL 60084

**Trade Name(s):** Max Blank

**Product:** Residential Room Heater/Fireplace (Wood)

**Pertinent Code Section(s):** 27-848

**Prescribed Test(s):** RS 14-21 (UL 1482), RS 15-15 (UL 127 Modified)

**Laboratory:** Omni Test Laboratories

**Test Report(s):** Report No. 276-S-06-2 Dated 4/20/05, Report No. 276-S-05-02 10/25/04, Report No. 276-S-04-02, Dated 11/3/04, Report No. 276-S-03-2 Dated 11/5/04

**Description** –It is a freestanding unit, it burns wood to give supplemental heating for space.

**Product Covered:** Niagara, Atlanta, Atlanta BF, Florenz, Heidelberg, Memphis, Ravenna, Rio, Frisco, Atlanta WP, Davos, Monza, Siena, Solero, Toulouse, Zitro and Bordeaux-K03. Sizes and ratings shall not exceed the sizes and ratings as mentioned by the Manufacturing Company.

**Terms and Conditions:** That the above described factory-built fireplaces be accepted for use as supplemental heating and decorative purposes. The installation of the above described units shall be in accordance with manufacturer supplied instructions and Section 27-848 of the Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code. All shipments and deliveries of

such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

**Notes:** Minimum clearance from combustible construction shall be in accordance with RS 14-15 of the Building Code.

Final Acceptance 7/7/06

Examined by Shyam. Prasad