

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 254-02-E
Report of Material and Equipment Acceptance Division

Manufacturer – Fire-Lite Alarms, One Fire-Lite Place, Northford, CT 06472-1001.

Trade Name(s) – Fire-Lite.

Product – Fire Alarm Control.

Pertinent Code Section(s) – 27-968, 27-977, Reference Standard RS 17, RS 17-5, ANSI/NFPA 72.

Test(s) – RS 17-5, ANSI/NFPA 72, UL 864.

Laboratory – Underwriters Laboratories, Inc.

Test Report(s) – UL File S711, Project No. 02NK03499, Vol. 1, Sec. 3 and Sec. 4, dated February 8, 2002 and February 11, 2002, and UL letter dated July 19, 2002.

Description – The UT-PS1 and UT-PS2 are single action manual pull boxes non-coded.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated August 16, 2002 F.P. Index #0208003.

Recommendation- That the above units be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and the UL listing. The reference product shall be used only with listed and approved fire control panels and accessories. The compatibility must be specified or determined by a UL Test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance August 27, 2002

Examined by Mark J. [Signature]