



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 254-05-E

Manufacturer: Manitowoc Ice Inc., 2110 South 26th Street,
Manitowoc, WI 54221

Trade Name(s): Manitowoc Ice

Product: Commercial refrigerators and freezers, remote
systems

Pertinent Code Section(s): 27-771, 27-772

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): File SA4027, dated November 18, 2003, revised
February 2, 2005.

Description: Commercial refrigerators and freezers for use with remote-condensing units in food stores. Units are comprised of on/off switches, remote-condensing units, inter-connecting refrigerant lines, expansion valves, refrigerant controllers and evaporators.

SD1272C, SY1274C – used with condensing unit **CVD1285**

SD1492N, SY1494N – used with remote section **JC1395**

SD1692N, SY1694N, SR1690N – used with remote section **JC1395**

SD1892N, SY1894N, SR1890N – used with remote section **JC1395**

Terms and Conditions: The above-described commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not interfere with accessibility for operation and servicing.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 1/4/07

Examined By Raymond Gross