

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 255-00-E

Report of Material and Equipment Acceptance Division

Manufacturer– American Standard Water Heater Corporation, 12910 Mulberry Drive, Whittier, California 90605.

Trade Name – American Standard, Duraglass.

Product – Residential electric water heaters.

Pertinent Code Section(s) – 27-787).

Prescribed Tests–RS 14-6 (UL 174).

Laboratory –Underwriters Laboratories Inc.

Test Report(s) – UL file E169649 dated January 18, 2000.

Description – Electric storage type water heaters, designed for residential installation. Unit comprises a glass-lined water storage tank covered by foam insulation, immersion-heating element(s) up to 54 kw, thermostat and manual reset temperature limiting device. Units are provided with means for permanent connection to electrical supply and to water supply, and opening for installation of temperature and pressure relief valve. Unit, with model numbers and storage capacities, are listed below:

| Model No. | Storage Capacity Gallons |
|-----------|--------------------------|
| CE-52 | 52 |
| CE-80 | 80 |
| CE-120 | 120 |

Note: Units may be installed in combustible flooring. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Recommendation - That the above described electric water heaters installed as per clearances to combustible construction specified above, under the following conditions:

1. Automatic ASME listed temperature and pressure relief valve, properly sized for heater and MEA accepted, shall be furnished for heater installation.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

AUG 24 2000

Final Acceptance _____

Examined By S. Deshpande