



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 255-06-E

Manufacturer: Josam Company
525 U.S. Hwy 20 West
Michigan City, Indiana 46360
Ph: 219-872-5531 Fx: 800-627-0008

Trade Name(s): Josam Company

Product: Manual Grease Interceptors

Pertinent Code Section(s): RS 16 – P105.4(d)(4).

Prescribed Test(s): ASME A112.14.3-2000 & PDI G-101

Laboratory: NSF International & Industrial Testing Labs

Test Report(s): J-00022144, J-00023142, S500682, S500861, S500860, S500589 & S500954

Description– Fabricated steel grease interceptor with acid resistant coating, inside and out.

MODEL NUMBER	FLOW GPM	CAPACITY LBS
60102H	7	14
60103H	10	20
60104H	15	30
60105H	20	40
60106H	25	50
60107H	35	70
60108H	50	100

Terms and Conditions: That the above kitchen grease interceptor be accepted on condition that all uses, locations and installations comply with the New York City Building Code Subchapter 16 and Reference Standard RS-16 Specifically Section P105.4 (d)(4) and the requirement of the Department of Environmental Protection.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance May 4, 2006.
Examined by Donald [Signature]