

DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Rudolph J. Rinaldi, R.A., Commissioner

MEA 257-91-M

Report of Material and Equipment Acceptance Division

Manufacturer - Matco Products, P.O. Box 27, Rt. 22, Brewster, New York 10509.

Trade Name - None.

Product - Gate Valve.

Pertinent Code Section - RS 17-6A.

Prescribed Tests - RS 17-6A (UL 262).

Laboratory - Underwriters Laboratories, Inc., Factory Mutual Research, Inc.

Test Reports - UL File 3594 Project 86NK15486, Project 87NK6041, Issued November 20, 1986; Revised November 20, 1987. FM File J.I. IN2A2.AH (1120) dated August 16, 1988.

Description - (Previous BSA File No. 77-91-M), gate valve for fire suppression system.

Model No.	Description	Size	Pressure Rating
105 U	O.S.Y. Flanged Gate Valve	2 1/2"-12	175 psig

Recommendation - That the above gate valves be accepted for fire suppression systems in accordance with their U.L. rating on condition that all uses, locations and installations comply with the New York City Building Code specifically subchapter 17 and Reference Standard RS-17.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use as provided for in Section 27-131 of the Building Code.

Final Acceptance 8/30/91
 Examined By Ma. J. [Signature]