

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Rudolph J. Rinaldi, R.A., Commissioner
MEA 257-91-N Vol. II

Report of Material and Equipment Acceptance Division
Manufacturer - Matco Products, Inc., P.O. Box 27, Route 22,
Brewster, New York 10509

Trade Name - Matco Products, Inc.

Product - Swing Check Valve-Model 120U.

Pertinent Code Sections - Reference Standard RS 17-6A.

Prescribed Tests - UL 312-1988; FM (1210).

Laboratory - Underwriters Laboratories, Inc. and Factory Mutual Research.

Test Report - UL File Ex3953, Project 86NK15487, Issued February 19, 1987,

FM file 1Q3Ao.Ah (1210) dated April 6, 1989.

Description - Swing Check Valve for fire suppression system.

Model No.	Description	Size	Pressure Rating
120 U	Swing Check Valve	2 1/2" - 10	175 PSI

Recommendation - That the above swing check valve be accepted for fire suppression systems in accordance with UL rating on condition that all uses, locations and installations comply with New York City Building Code specifically subchapter 17, and Reference Standard Rs-17. All shipments and deliveries of such equipment shall be provided with metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/2/92
Examined by Mano Jose Reyes