



NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 258-04-E Vol. 2

Manufacturer: Joslyn Clark Controls, LLC, 2013 West Meeting Street, Lancaster, S.C. 29720

Trade Name(s): Joslyn Clark Controls

Product: Fire Pump Controllers for Electric Motor-driven Fire Pumps

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS 17

Prescribed Test(s): FM Approval Standard Class No. 1321/1323 and NFPA 20

Laboratory: Factory Mutual Approvals (FM)

Test Report(s): Project Identifier No. 3032556 issued May 2, 2008.

Description: The Series "E" Bulletin Model 10600 full-service electric motor-driven fire pump controllers:

Series "E" Bulletin No. 10600. Cat. No. Eabed-efg⁽¹⁾

a = Starter type / Bulletin: 2, 3, 4, 5, 7, 8, 9 (10620, 10630, 10640, 10650, 10670, 10680, 10690)

b = Short circuit current rating: B, C, D, E

c = Horsepower rating: 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29.

d = Voltage and frequency: 2, 3, 4, 5, 6, 7, 8.

e = Pressure switch rating: 0, 4, 5, 7, 8, N+.

f = Transfer switch type: T, TU, Blank-no transfer switch.

g = Modification option: C, D1, D3, D4, D5, D6, E, E6, F0, F5, F8, F11, F12, F21, F22, F32, F33, G, G1, H1, H2, H3, J, J1, J21, J22, K, L, M, N, N1, P1, P2, P3, R2, R5, R7, S1, S3, S4, S5, S6, S7, S81, S82, T, TU, V, W1, W2, Y, 3R, 12, 4P, 4X, Z or Blank.

⁽¹⁾Use of a voltage surge arrestor is optional for this controller.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections (letter dated June 26, 2008, F.P. Index #0806050).

Terms and Conditions: The above units are accepted on condition that:

1. These controllers shall be installed to operate only the fire pumps that are UL-listed and provided with MEA resolution approval.
2. Each fire pump shall be provided with its own controller. No other electrical equipment, including any jockey pump (pressure maintenance pump) shall be powered from the fire pump controller.
3. The power supply, the installation and use of these fire pump controllers shall be in accordance with the requirements of New York City Electrical Code, specifically Article 695.
4. Factory Mutual's and manufacturer's installation, maintenance procedures and limitations shall be complied with.
5. All uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17. Further, the installation shall be in accordance with NFPA 20 and FM standard.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance August 4, 2008
Examined By [Signature]