



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 26-06-E

Manufacturer: Progressive Manufacturing 20 Air Park Road
 West Lebanon, NH 03784

Trade Name(s): Vision Fireplace

Product: Gas-fired vented decorative fireplace appliance

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.50, Z21.88a, Z21.11, Z21.44)

Laboratory: Omni Test Lab

Test Report(s): No. 284-F-01-5, dated November 22, 2004

Description: Gas-fired decorative fire place appliance designed to provide supplemental heating and to enhance the aesthetics of a room.

Model No.	Max Input Rating BTUH
Vision Z C Fireplace	45,000

Terms and Conditions: The above-described gas-fired vented appliance is accepted for decorative heating operation on the following conditions:

1. Natural gas to be used only.
2. Clearance to combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
3. For indoor installation only with combustion air and required ventilation air provided. Venting of fireplace is subject to Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and delivery of such equipment shall be accompanied by a metal tag permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance 4/2/2006

Examined by Stephen M. Jansen