

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner
MEA 261-00-M

Report of Material and Equipment Acceptance Division

Manufacturer – G.A.L. Manufacturing Corp., 50 East 153rd Street, Bronx, NY 10451.

Trade Name – G.A.L.

Product - Elevator door interlock assemblies.

Pertinent Code Section(s) - 27-990.

Prescribed Test(s) - RS 18-1 (ANSI A17.1).

Laboratory - Canadian Standard Association.

Test Report(s) - File LR13004-20 dated November 26, 1998.

Description – Type MO Series Elevator Door Interlock (model numbers MO, MOM, MO10, MOH, MOCPSH, MOCPSHC) is specifically designed for use on side opening horizontally sliding elevator hoistway doors. This device locks and prevents the door from opening unless the elevator car is properly in position, and also prevents operation of the elevator driving machine unless the door is locked in the closed position. This interlock is operated by a clutch mounted on the car door.

Model Series designations are as follows:

MO	One roller
MOM	Two rollers mounted vertically
MO10	Two rollers mounted on keeper
MOH	Two rollers mounted horizontally
MOCPSH	Using MOCPS box (single contact)
MOCPSHC	Same as above with reel closer mounting for Type "C" hanger

Recommendation - That the above described electro-mechanical elevator door interlocking device be accepted, when installed and adjusted as per manufacturer's instructions, subject to the approval of elevator inspection department at the installation site. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided by a metal tag, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance Nov. 22, 2000

Examined By S Derkhdam