



NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### **MEA 262-05-E**

**Manufacturer:** Grandview Sheetmetal Fabricator Corp., 62 Hope Street, Brooklyn, NY 11211.

**Trade Name(s):** Grandview Sheetmetal.

**Product:** Baffle type grease filters for use in commercial kitchen exhaust ducts.

**Pertinent Code Section(s):** Reference Standard RS 13-3.

**Prescribed Test(s):** RS 13-3 (UL 1046).

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** File R22015 dated March 30, 2005.

**Description** – Baffle type grease filter is made from stainless steel or galvanized steel sheets. Dimensions are 20" x 20" x 1 ¾", 25" x 20" 1 ¾", 25" x 16". They are intended for installation in exhaust hood for restaurant type cooking equipment.

### **Product Covered:**

Baffle type grease filters, Model "GV" followed by suffix: 20 x 20, 25 x 20, 25 x 16, with 1 ¾" deep.

**Terms and Conditions:** That the above stainless steel or galvanized steel baffle grease filters used in kitchen hoods, be accepted on condition that all uses, locations and installations comply with the New York City Building Code, specifically with Reference Standard RS 13-3 and o further condition that:

1. Installation, maintenance cleaning procedures and use shall comply with RS 13-3 of the Building Code and all applicable New York City codes, rules, regulations and maintenance requirements.
2. Underwriters Laboratories Inc.'s listing requirements and limitations shall be complied with.
3. Manufacturer's installation, maintenance procedures and limitation shall be complied with.
4. RS 13-3 prohibits the use of dampers in exhaust duct systems.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

9/21/01

Examined By

Shyam. Das