



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 27-06-E

Manufacturer: Wolf Steel LTD. 24 Napoleon Road Barrie, Ont. L4M 4YB.

Trade Name(s): Napoleon Fireplaces

Product: Gas Fired Decorative Log Appliance

Pertinent Code Section(s): 27-800

Test(s): RS 14-6 (ANSI Z21.60a)

Laboratory: Underwriters Laboratories

Test Report(s): File MH29818, dated January 9, 2005

Description – Gas Fired Decorative Log Appliance is designed to provide supplemental heating and to enhance the aesthetics of a room. The logs are ceramic and are designed to be numbers and their input BTU ratings are also listed as follows:

Model No.	Type	Input (BTUH)	Output (BTUH)	Test report
GL18	Vented Gas Logs	55000	N/A	MH29818, 7/18/2005
GL24	Vented Gas Logs	60000	N/A	MH29818, 7/18/2005
GL30	Vented Gas Logs	65000	N/A	MH29818, 7/18/2005

Note: Clearance from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.

Terms and Conditions: The above described Gas Fired Log appliance be accepted for use in vented fireplaces only, for decorative heating operation on natural gas and for indoor installation only with combustion air and required ventilation air provided. Vending of the fireplace is subject to Section 27-879 of the Building Code. All shipment and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the Building Code.

Final Acceptance 5/1/06
Examined by Sheyam. Prasad