



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 273-05-E

**Manufacturer:** Hussong Manufacturing Co., Inc. 204 Industrial Park Drive, Lakefield, MN 56150

**Trade Name(s):** Kozy Heat

**Product:** Factory-built, direct-vent gas-fired heaters and decorative appliances

**Pertinent Code Section(s):** 27-800, RS 14-2 (ANSI Z 21.88)

**Prescribed Test(s):** RS 14-6 (ANSI Z21.50- 1992, ANSI Z21.44, Z21.88)

**Laboratory:** AMNI- Test Lab

**Test Report(s):** 216-F-07-5 dated April 17, 2005, 216-F-08-5 dated June 5, 2005, and 216-S-05-5 dated August 5, 2005.

**Description:** Factory-built, direct-vent gas fireplace heater (fireplace) designed to provide supplemental heating and to enhance the aesthetics of a room.

Model No. & Name	Description	Gas Type	BTU Input/Hr
#55345 Minnetonka	Vented Gas Fireplace Heater	Natural Gas	40,000
#55616 Two Harbors	Vented Gas Fireplace Heater	Natural Gas	14,600
#56701 Thief River Falls	Vented Gas Fireplace Heaters	Natural Gas	28,000
#55801 Duluth	Vented Gas Fireplace Heaters	Natural Gas	23,000
#911-XXL	Vented Gas Fireplace Heaters	Natural Gas	42,000

**Terms and Conditions:** The above-described factory-built, fireplaces are accepted for use as supplemental heating and decorative purposes with the following conditions:

1. Units shall be fired with natural gas only.
2. Units shall be installed in accordance with manufacturer's supplied instructions, and all installations, uses and locations shall comply with Subchapters 14, Article 19, Solid Fuel Fireplaces, Fireplace Stoves, and Room Heaters, and Subchapter 15, Article 2, Chimneys, of the New York City Building Code, and UL listing. Furthermore, units shall be vented in accordance with Section 27-856 of the Building Code.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the New York City Building Code.

Final Acceptance 6/24/07

Examined by Shyam. [Signature]