



## Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 279-05-M

**Manufacturer:** STOVeroTec GmbH, Hanns- Martin Schleyer- Strabe- 1  
Lawingen/Donau, Germany D- 89415.

**Trade Name(s):** STOsilent Panel System, Pyrok

**Product:** Acoustic Plaster Panel System.

**Pertinent Code Section(s):** 27-348.

**Prescribed Test(s):** RS 5-5 (ASTM E 84), Toxicity.

**Laboratory:** VTEC Laboratories Inc.

**Test Report(s):** V100-2203-3- V100-2203-4-

**Description-** Acoustical panels manufactured from recycled crushed glass and coated with plaster finish, which can be cut into a seamless system. The panel is low weight and high rigidity for ease of installation. No fibers present. Panels are non-sensitive to humidity. Panels can be cut with handsaw or jigsaw.

Flamespread Rating – 15; Smoke density – 15

**Terms and Conditions** – That the above described solid surfacing material be accepted for interior finish usage, Class A flame spread and smoke developed rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustion that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance SEP/16/2005  
Examined By S Derkhotam