



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 28-07-E

Manufacturer: American Panel Corp., 5800 S.E. 78th Street, Ocala, FL 34471

Trade Name(s): American Panel

Product: Commercial refrigerators and freezers, remote systems

Pertinent Code Section(s): 27-771, 27-772

Prescribed Test(s): RS 14-6 (UL 471)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File SA32188, dated September 13, 2006, revised November 18, 2006

Description: HurriChill commercial refrigerators and freezers for use with remote condensing units in food stores. Units are comprised of on/off switches, remote condensing units, inter-connecting refrigerant lines, expansion valves, refrigeration controllers and evaporators.

Model Nos.	Description
AP20BCF175-3, AP40BC350-3, AP40BCF450-3, AP24BC250-3, AP24BCF300-3, AP80BC700-3, AP80BCF900-3, AP120BC1000-3, AP120BCF1300-3, AP40BC250-12, AP40BC250-2-12, BCCP-1, BCCP-2, BCIP	HurriChill Remote Roll-in Blast Chiller/Shock Freezers
APC3BCF30-1, AP4BCF45-2, AP7BCF70-2, AP12BCF110-3	HurriChill Remote Blast Chiller/ Shock Freezers

Terms and Conditions: The above-described commercial refrigerators and freezers are accepted under the following conditions:

1. Units shall be installed in accordance with manufacturer's instructions and New York City Electrical and Building Code requirements.
2. Adequate supply of fresh air shall be provided into room or space enclosing equipment for ventilation.
3. The installation shall not obstruct required access for operation and servicing.
4. No flammable material (except electrical insulation) shall be located in the machine or wiring compartments unless specified.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 2/23/07

Examined By *Dyan. [Signature]*