

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Satish K. Babbar, R.A., Acting Commissioner  
MEA 281-00-E

Report of Material and Equipment Acceptance Division

Manufacturer – Altronix Corp., 140 58<sup>th</sup> Street, Brooklyn, New York 11220.

Trade Name(s) – Altronix Corp., Rofu International Corp.

Product – Power Supplies for Access Control.

Pertinent Code Section(s) – Reference Standard RS-17.

Prescribed Test(s) – UL 294, UL 1012.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File BP6714, Project 97ME20343, issued January 12, 1998 and revised December 28, 1999 and UL letter dated July 20, 2000.

Description – Model AL175ULX2 is a 12/24 VDC power supply used for Access Control Systems. The unit is designed to charge sealed lead acid type rechargeable batteries and is designed to provide power with a max resistive load of 1.75A at 12 or 24 VDC. It is multiple listed as follows:

Basic Applicant's (Supplier's) Product Designation Altronix Corp.	Multiple Listee's Product Designation Rofu International Corp.
AL175ULX2	9175

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated September 11, 2000, F.P. Index No. 0009008.

Recommendation - That the above power switches be accepted on conditions that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3, the manufacturer's recommendations, NFPA 72, and UL Standard and on further condition that:

1. The power supply to this unit must be un-switched and un-interruptible.
2. The connection of security/burglar devices and equipment to a fire alarm system shall be prohibited.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 17, 2000

Examined By Mark J. Kelly